

## 4-8 Ferndell St SOUTH GRANVILLE NSW 2142

PO Box 3107 WETHERILL PARK NSW 2164

Ph: (02) 9632-5000 Fax: (02) 9632-5011 ABN: 18 165 515 257

## PRODUCT DATA AND APPLICATION SHEET

PRODUCT NAME Residual Current Device (HPL5 Series)

**DESCRIPTION** Residual Current Device (RCD), available in 4 module, Current rating in 40 Amp and

63 Amp, 250V, 30mA sensitivity.

PRODUCT CODE TRCD4P40, TRCD4P63

**FEATURES** 

• Sensitive and fleetly protection;

PA66 reinforced fire-resistant body;

Short-circuit capacity up to 6kA;

Din rail mounting EN 5022;

Operating Temp -5 to 40deg

• Size 81mm x 72mm x 75mm

## **TECHNICAL DATA**

	TRCD4P40, TRCD4P63
Standard	IEC61008-1
Number of Poles	4 Pole
Rated Voltage	415V
Rated Current	40A, 63A
Conditioned rated short-circuit current Iq	6kA
Curve code	С
Degree of Protection (IP) front side	IP20
Modular Spacing	4 pole 72mm,
Approval No	ESV130155
Box Quantities	1



